



ANALOGUE INSULATION TESTER KEW 3431



KEW 3431 Specifications

| Insulation resistance | | | | | |
|-----------------------|--|---|---|--------------|--|
| | Test voltage | 250V | 500V | 1000V | |
| | Max. effective scale value | 200ΜΩ | | 2000ΜΩ | |
| | Mid-scale value | 5ΜΩ | | 50ΜΩ | |
| | First effective measuring ranges | 0.1ΜΩ - 100ΜΩ | | 1ΜΩ - 1000ΜΩ | |
| | Accuracy | ±5% of indicated value | | | |
| | Second effective measuring ranges | Measuring ranges | easuring ranges other than above, 0 and ∞ | | |
| | Accuracy | $\pm 10\%$ of indicated value | | | |
| | LED insulation state indicator | 0.25ΜΩ | 0.5ΜΩ | 1ΜΩ | |
| | indicating result by red / green color | | | | |
| Voltage measurement | | | | | |
| | Voltage range | AC 600V [45 - 65Hz]/DC 600V | | | |
| | Accuracy | $\pm 5\%$ of full scale value | | | |
| Applicable Standards | | IEC 61010-1, 2-030 CAT Ⅲ 600V, IEC 61557-1, -2 | | | |
| | | IEC 61010-031, IEC 61326(EMC), EN 50581(RoHS) | | | |
| Power source | | $LR6/R6(AA)(1.5V) \times 4$ | | | |
| Dimensions / Weight | | 97(L) × 156(W) × 46(D)mm / 430g approx. | | | |
| Included Accessories | | 7260(Test lead with remote control switch), | | | |
| | | 7261(Test lead with alligator clip), 9173(Carrying case), | | | |
| | | 8017A(Extension prod long), 9121(Shoulder strap), | | | |
| | | LR6(AA) × 4, Instruction manual | | | |
| Optional Accessories | | 7243(L-shaped probe), 8016(Hook type prod) | | | |

Included Accessories






Test lead with remote control switch (1,400mm)



Test lead with alligator clip (1,400mm)








9121 Shoulder strap

Optional Accessories











Test leads with remote control switch supplied as standard accessories.



Protective carry case with easy access to test leads.



turns the illuminated

scale and LED spot light ON/OFF.



Battery status LED



RED: AC



RED: Replace

Protection against unintentional selection of 1000V range

There is an empty range selection (space) between 500V and 1000V ranges.





Please read the "Safety Warnings" in the instruction manual supplied with the instrument thoroughly and completely Safety Warnings: for correct use. Failure to follow the steet rules can cause fire, trouble, electrical shock, etc. Therefore, make sure to operate the instrument on a correct power supply and voltage rating marked on each instrument.

For inquires or orders:



KYORITSU ELECTRICAL **INSTRUMENTS** WORKS, LTD.

2-5-20, Nakane, Meguro-ku, Tokyo, 152-0031 Japan Phone:+81-3-3723-0131 Fax:+81-3-3723-0152 E-mail:info-eng@kew-ltd.co.jp

http://www.kew-ltd.co.jp